

Indian Creek WTP

CODE	SERVICE AREA	STREET	SAMPLE DATE	SAMPLE TIME	Lead results	Copper results
801	Everson	Maple St.	8/20/2016	5:30	<0.005 mg/l	0.035 mg/l
802	Greensburg	Ridgeview Drive	8/28/2016	9:45	<0.005 mg/l	0.032 mg/l
804	Everson	Painter St.	8/19/2016	9:00	<0.005 mg/l	0.038 mg/l
805	Everson	Chestnut St	8/19/2016	8:30	<0.005 mg/l	0.042 mg/l
806	Everson	Jones St	8/18/2016	9:40	<0.005 mg/l	0.072 mg/l
807	Everson	Jones St	8/19/2016	6:00	<0.005 mg/l	0.094 mg/l
808	Greensburg	Chestnut St	8/20/2016	7:30	<0.005 mg/l	0.028 mg/l
809	Greensburg	Berky Acres Rd	9/8/2016	6:00	<0.005 mg/l	0.113 mg/l
810	North Versailles	Third St.	9/8/2016	7:00	<0.005 mg/l	0.060 mg/l
811	Everson	Maple St	8/18/2016	15:30	<0.005 mg/l	0.034 mg/l
812	North Huntington	N Whitmore Rd	9/8/2016	4:00	<0.005 mg/l	0.027 mg/l
813	Greensburg	Welty St.	8/17/2016	5:00	<0.005 mg/l	0.013 mg/l
814	Greensburg	Ridge Rd	8/24/2016	6:45	<0.005 mg/l	0.125 mg/l
815	Greensburg	Wyoming St	8/27/2016	7:20	<0.005 mg/l	0.079 mg/l
816	Greensburg	Laurel Dr	8/27/2016	5:30	<0.005 mg/l	0.065 mg/l
817	Greensburg	Seminary Ave.	8/17/2016	7:00	<0.005 mg/l	0.033 mg/l
818	Youngwood	S 5th St	8/25/2016	6:13	<0.005 mg/l	0.061 mg/l
819	Greensburg	Mace St.	8/16/2016	5:20	<0.005 mg/l	0.050 mg/l
820	Greensburg	Mace St	8/16/2016	6:30	<0.005 mg/l	0.000 mg/l
821	Greensburg	Mace St	8/17/2016	6:40	<0.005 mg/l	0.025 mg/l
822	Greensburg	Green St	8/27/2016	3:30	<0.005 mg/l	0.046 mg/l
823	Greensburg	Elm St	8/28/2016	8:00	<0.005 mg/l	0.055 mg/l
824	Greensburg	Green St	8/17/2016	8:47	<0.005 mg/l	0.064 mg/l
825	Greensburg	Oakland Ave.	8/17/2016	20:11	0.031 mg/l	0.111 mg/l
827	Greensburg	Alexander St.	8/17/2016	10:20	<0.005 mg/l	0.081 mg/l
828	Greensburg	Alexander St.	8/25/2016	4:12	<0.005 mg/l	0.040 mg/l
829	Greensburg	Mitinger Ave	8/29/2016	6:30	<0.005 mg/l	0.063 mg/l
830	Mt. Pleasant	Eagle St.	8/19/2016	7:20	<0.005 mg/l	0.033 mg/l
831	Mt. Pleasant	Eagle St	8/19/2016	8:40	<0.005 mg/l	0.032 mg/l
832	Mt. Pleasant	Eagle St.	8/19/2016	9:00	<0.005 mg/l	0.080 mg/l
833	Scottdale	Dubois St	9/8/2016	3:30	<0.005 mg/l	0.073 mg/l
834	Mt. Pleasant	Eagle St	8/19/2016	14:15	<0.005 mg/l	0.049 mg/l

Indian Creek WTP continued

CODE	SERVICE AREA	STREET	SAMPLE DATE	SAMPLE TIME	Lead results	Copper results
835	Mt. Pleasant	S. Quarry St.	8/20/2016	10:25	<0.005 mg/l	0.067 mg/l
836	Mt. Pleasant	Brook Hollow	8/24/2016	6:50	<0.005 mg/l	0.051 mg/l
837	Scottsdale	Park Avenue	9/8/2016	5:00	<0.005 mg/l	0.041 mg/l
839	Mt. Pleasant	N Church St	8/27/2016	6:00	<0.005 mg/l	0.065 mg/l
840	Mt. Pleasant	Parkview Terrace	8/19/2016	6:44	<0.005 mg/l	0.026 mg/l
841	Mt. Pleasant	Parkview Terrace	8/19/2016	5:15	<0.005 mg/l	0.052 mg/l
842	Mt. Pleasant	James Way	8/19/2016	5:30	<0.005 mg/l	0.042 mg/l
843	Rostraver	Chestnut St	8/24/2016	6:00	<0.005 mg/l	0.026 mg/l
844	West Newton	Venebale St	8/24/2016	5:30	<0.005 mg/l	0.092 mg/l
845	West Newton	Lantern Lane	9/8/2016	6:28	<0.005 mg/l	0.019 mg/l
846	West Newton	Blackburn St	8/23/2016	9:45	<0.005 mg/l	0.023 mg/l
847	West Newton	N. Water St	8/24/2016	7:13	<0.005 mg/l	0.018 mg/l
848	West Newton	Blackburn St	8/23/2016	21:45	<0.005 mg/l	0.000 mg/l
849	West Newton	W. Main St	8/23/2016	16:00	<0.005 mg/l	0.033 mg/l
850	West Newton	N. Water St	8/24/2016	6:16	<0.005 mg/l	0.059 mg/l
851	West Newton	N Second St	8/24/2016	9:44	<0.005 mg/l	0.158 mg/l
853	Greensburg	Wyoming St	9/9/2016	5:07	<0.005 mg/l	0.053 mg/l
854	Greensburg	Mace St	8/16/2016	10:00	<0.005 mg/l	0.070 mg/l
856	Greensburg	Degregory Drive	8/27/2016	6:30	<0.005 mg/l	0.032 mg/l
857	Greensburg	Oakland Ave.	8/17/2016	8:20	<0.005 mg/l	0.045 mg/l
858	West Newton	Blackburn St.	8/24/2016	6:10	<0.005 mg/l	0.024 mg/l

Note: All of the MAWC Sample sites for the 2016 Monitoring period were reevaluated under the existing Lead and Copper Rule Materials evaluation. From this information, all of the sample sites listed were determined to be "Tier I" Sites, as defined by the EPA rule. According to this rule, a Tier I site is: A single family structures that: (i) Contain copper pipes with lead solder installed after 1982 or contain lead pipes; and/or (ii) Are served by a lead service line.

George Sweeney WTP

CODE	SERVICE AREA	STREET	SAMPLE DATE	SAMPLE TIME	Lead results		Copper results	
891	Vandergrift	Sycamore	9/16/16	12:30	<0.005	mg/l	0.133	mg/l
894	Jeannette	N. 2nd st	8/31/16	5:00	<0.005	mg/l	0.036	mg/l
895	Murrysville	Foxwood	9/22/16	6:45	<0.005	mg/l	0.063	mg/l
896	Hannastown	Pollins	9/22/16	5:00	<0.005	mg/l	0.076	mg/l
897	Trafford	Meadowbrook	9/22/16	7:42	<0.005	mg/l	0.055	mg/l
898	Murrysville	Marjorie	9/22/16	5:14	<0.005	mg/l	0.06	mg/l
899	Jeannette	12th St	9/13/16	7:00	<0.005	mg/l	0.01	mg/l
906	N. Huntingdon	Bluebird	8/31/16	6:30	<0.005	mg/l	0.048	mg/l
911	Irwin	Renaissance	8/31/16	6:00	<0.005	mg/l	0.043	mg/l
913	Vandergrift	Hancock	9/6/16	10:00	0.138	mg/l	0.136	mg/l
914	Vandergrift	Beech	9/8/16	6:10	0.005	mg/l	0.122	mg/l
918	Apollo	Reservoir Rd.	9/16/16	7:05	<0.005	mg/l	0.112	mg/l
920	Irwin	Pennsylvania Ave	8/31/16	8:43	<0.005	mg/l	0.111	mg/l
924	Vandergrift	Hancock	9/7/16	6:00	<0.005	mg/l	0.111	mg/l
929	Trafford	William Dr	9/12/16	8:16	<0.005	mg/l	0.073	mg/l
931	Murrysville	N. Hills	9/15/16	7:00	<0.005	mg/l	0.062	mg/l
933	Vandergrift	Beech	9/7/16	5:30	<0.005	mg/l	0.06	mg/l
939	N. Huntingdon	Cedar Glenn	8/31/16	9:55	<0.005	mg/l	0.076	mg/l
941	Vandergrift	Emerson st	9/22/16	6:00	<0.005	mg/l	0.014	mg/l
942	Jeannette	Moore Ave	9/13/16	7:30	<0.005	mg/l	0.095	mg/l
943	Vandergrift	Hancock	9/17/16	8:30	<0.005	mg/l	0.047	mg/l
950	N. Huntingdon	Sherman ave	8/31/16	7:00	<0.005	mg/l	0.093	mg/l
951	Vandergrift	Cooper St	9/16/16	5:30	<0.005	mg/l	0.037	mg/l
954	Vandergrift	Hancock	9/6/16	20:00	<0.005	mg/l	0.054	mg/l
957	N. Huntingdon	Reed	8/31/16	5:00	<0.005	mg/l	0.035	mg/l
959	Apollo	S. Pennsylvania Ave.	9/16/16	6:00	<0.005	mg/l	0.026	mg/l
961	Jeannette	Harrison Ave	8/31/16	6:30	<0.005	mg/l	0.047	mg/l
962	Vandergrift	Franklin ave	9/16/16	7:30	<0.005	mg/l	0.089	mg/l
963	Irwin	Chestnut st	8/31/16	5:00	<0.005	mg/l	0.073	mg/l
965	Vandergrift	Poplar st	9/15/16	6:00	<0.005	mg/l	0.113	mg/l
967	Vandergrift	Bryant	9/16/16	5:50	<0.005	mg/l	0.02	mg/l
968	Apollo	Highland	9/16/16	7:50	<0.005	mg/l	0.296	mg/l

George Sweeney WTP continued

CODE	SERVICE AREA	STREET	SAMPLE DATE	SAMPLE TIME	Lead results		Copper results	
973	Export	Webster St	9/13/16	8:00	<0.005	mg/l	0.012	mg/l
974	Jeannette	S. 14th st	9/13/16	8:00	<0.005	mg/l	0.051	mg/l
975	Irwin	Pennsylvania Ave	8/31/16	6:55	<0.005	mg/l	0.044	mg/l
977	Vandergrift	Sycamore	9/16/16	8:00	<0.005	mg/l	0.044	mg/l
980	Vandergrift	Beech	9/8/16	8:00	<0.005	mg/l	0.047	mg/l
981	Apollo	N. 5th St	9/7/16	7:18	<0.005	mg/l	0.011	mg/l
983	Vandergrift	Beech St	9/7/16	6:30	0.005	mg/l	0.047	mg/l
987	Irwin	Victoria Lane	9/13/16	7:15	<0.005	mg/l	0.085	mg/l
990	Apollo	N. 7th St	9/7/16	8:40	<0.005	mg/l	0.082	mg/l
991	Vandergrift	Longfellow St	9/7/16	7:03	<0.005	mg/l	0.039	mg/l
992	Vandergrift	Hancock	9/7/16	6:00	<0.005	mg/l	0.055	mg/l
994	Jeannette	Ellsworth	8/31/16	6:20	<0.005	mg/l	0.115	mg/l
995	N. Huntingdon	Katherine Drive	8/31/16	8:00	<0.005	mg/l	0.027	mg/l
996	Vandergrift	Beech	9/8/16	7:51	<0.005	mg/l	0.04	mg/l
997	Delmont	Kenneht Drive	9/12/16	21:00	<0.005	mg/l	0.072	mg/l
998	Apollo	Grange Drive	9/16/16	6:20	<0.005	mg/l	0.028	mg/l
999	Leechburg	Beecher ct	9/13/16	4:00	<0.005	mg/l	0.041	mg/l
993	Vandergrift	Hancock	9/6/16	5:50	0.007	mg/l	0.07	mg/l

Note: All of the MAWC Sample sites for the 2016 Monitoring period were reevaluated under the existing Lead and Copper Rule Materials evaluation. From this information, all of the sample sites listed were determined to be "Tier I" Sites, as defined by the EPA rule. According to this rule, a Tier I site is: A single family structures that: (i) Contain copper pipes with lead solder installed after 1982 or contain lead pipes; and/or (ii) Are served by a lead service line.

McKeesport WTP

CODE	SERVICE AREA	STREET	SAMPLE DATE	SAMPLE TIME	Lead results	Copper results
710	McKeesport	Tulip Dr.	9/10/2016	7:00	<0.005 mg/l	0.093 mg/l
712	McKeesport	James St.	9/11/2016	7:01	<0.005 mg/l	0.041 mg/l
726	McKeesport	Beale St.	9/14/2016	5:00	<0.005 mg/l	0.057 mg/l
717	McKeesport	Pacific Ave.	9/14/2016	7:00	<0.005 mg/l	0.070 mg/l
721	McKeesport	O'Neil Blvd.	9/14/2016	7:30	<0.005 mg/l	0.434 mg/l
725	Port Vue	Morton Ave.	9/15/2016	4:45	<0.005 mg/l	0.123 mg/l
714	McKeesport	Calvin St.	9/15/2016	5:00	<0.005 mg/l	0.086 mg/l
720	McKeesport	Banker St.	9/15/2016	6:00	<0.005 mg/l	0.036 mg/l
713	McKeesport	Dalton St.	9/15/2016	6:35	<0.005 mg/l	0.077 mg/l
701	McKeesport	Orofino St.	9/15/2016	7:00	<0.005 mg/l	0.031 mg/l
706	Port Vue	Beverly Rd.	9/15/2016	7:00	<0.005 mg/l	0.036 mg/l
724	White Oak	Eisenhower Ct.	9/14/2016	4:15	<0.005 mg/l	0.093 mg/l
718	McKeesport	Garbett St.	9/14/2016	4:44	<0.005 mg/l	0.055 mg/l
722	White Oak	Oliver Dr.	9/14/2016	5:15	<0.005 mg/l	0.097 mg/l
756	White Oak		9/14/2016	6:27	<0.005 mg/l	0.037 mg/l
709	McKeesport	Third St.	9/14/2016	7:45	<0.005 mg/l	0.033 mg/l
715	McKeesport	Beckman Dr.	9/14/2016	8:30	<0.005 mg/l	0.029 mg/l
708	White Oak	Hill St.	9/15/2016	7:00	<0.005 mg/l	0.100 mg/l
729	McKeesport	Grandview Ave.	9/15/2016	8:00	<0.005 mg/l	0.074 mg/l
716	Versailles	High St.	9/16/2016	5:00	<0.005 mg/l	0.052 mg/l
723	McKeesport	Freemont St.	9/18/2016	7:30	<0.005 mg/l	0.064 mg/l
705	McKeesport	Wesley St.	9/20/2016	8:55	<0.005 mg/l	0.053 mg/l
740	McKeesport	Calvin St.	9/22/2016	7:00	<0.005 mg/l	0.031 mg/l
739	McKeesport	Washington St.	9/22/2016	8:00	<0.005 mg/l	0.062 mg/l
741	McKeesport	Ann St.	9/22/2016	21:30	<0.005 mg/l	0.026 mg/l
745	McKeesport	Washington St.	9/23/2016	7:04	<0.005 mg/l	0.031 mg/l
742	McKeesport	Lewis St.	9/27/2016	8:00	<0.005 mg/l	0.073 mg/l
743	White Oak	Jefferson St.	9/27/2016	6:25	<0.005 mg/l	0.047 mg/l
749	McKeesport	Halsey St.	9/29/2016	5:15	<0.005 mg/l	0.091 mg/l
747	White Oak	Kansas Ave.	9/28/2016	5:00	<0.005 mg/l	0.045 mg/l

McKeesport WTP continued

Note: All of the MAWC Sample sites for the 2016 Monitoring period were reevaluated under the existing Lead and Copper Rule Materials evaluation. From this information, all of the sample sites listed were determined to be "Tier I" Sites, as defined by the EPA rule. According to this rule, a Tier I site is: A single family structures that: (i) Contain copper pipes with lead solder installed after 1982 or contain lead pipes; and/or (ii) Are served by a lead service line.

Johnstown Water Supply- Furnace Run WTP

CODE	SERVICE AREA	STREET	SAMPLE DATE	SAMPLE TIME	Lead results	Copper results
17	Ligonier	W Main st	9/20/2016	8:40	<0.005 mg/l	0.191 mg/l
4	Ligonier	N Clair st	9/20/2016	7:15	<0.005 mg/l	0.136 mg/l
22	Ligonier	N Market	9/20/2016	5:45	<0.005 mg/l	0.113 mg/l
2	Ligonier	Summit Ave	9/20/2016	5:39	<0.005 mg/l	0.098 mg/l
7	Ligonier	E Loyalhanna st	9/20/2016	7:00	<0.005 mg/l	0.136 mg/l
23	Ligonier	Summit Ave	9/20/2016	7:45	<0.005 mg/l	0.029 mg/l
12	Ligonier	E Church st	9/20/2016	7:15	<0.005 mg/l	0.125 mg/l
19	Ligonier	W Loyalhanna st	9/20/2016	9:30	<0.005 mg/l	0.104 mg/l
13	Ligonier	Summit Ave	9/20/2016	8:00	<0.005 mg/l	0.182 mg/l
1	Ligonier	W Main st	9/20/2016	10:30	<0.005 mg/l	0.038 mg/l

Note: All of the MAWC Sample sites for the 2016 Monitoring period were reevaluated under the existing Lead and Copper Rule Materials evaluation. From this information, all of the sample sites listed were determined to be "Tier I" Sites, as defined by the EPA rule. According to this rule, a Tier I site is: A single family structures that: (i) Contain copper pipes with lead solder installed after 1982 or contain lead pipes; and/or (ii) Are served by a lead service line.